

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2003 IPC

DATE:

CODE REF: IPC 1002.4

5/13/2004

SUBJECT: Product Approval ("**Trap Guard**")

5/13/2005

Buddy Bullock
Sales Manager
1355 Capital Circle
Lawrenceville, GA 30043

RE: ProSet Trap Guard™

Mr. Buddy Bullock,

I have reviewed your request for approval of the "ProSet Trap Guard™". I have concluded from the information submitted to my office for approval this product is not approved for the following reason for use within the City of Dallas.

The 2000 International Plumbing Code States the following:

P706.2 Obstructions. The fittings shall not have ledges, shoulders or reductions capable of retarding or obstructing flow in the piping. Threaded drainage pipe fittings shall be of the recessed drainage type.

Until your product conforms to the prevailing code and has received local approval your product may not be used in the City of Dallas.

I appreciate the opportunity to review your product and look forward to reviewing it again when it complies with the applicable codes namely the 2003 International Residential Code and International Plumbing Code.

Best Regards,

Lonnie Erwin

Lonnie Erwin
Chief Plumbing and Mechanical Inspector
Development Services
Building Inspection
City of Dallas

SIGNATURE: *Lonnie Erwin,*

Chief Plumbing and Mechanical Inspector
City of Dallas