

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: NFPA 99C

DATE:

CODE REF:

4/1/2004

SUBJECT: Med-Gas Inspections

Question: What are the points for consideration for a Med-Gas inspection?

Answer: The following points should be considered when performing a Med-Gas Inspection:

1. Materials
2. Support
3. Location of Piping
4. Location of Service Valves
5. Gas Central Supply System
 - a. Pressure Relief Valves
6. Medical Air Compressor Supply System
 - a. Compressor Intake
7. Proper labeling
8. Cleaning
9. Pressure Testing
10. Obtain Copies of Pressure Test Record and Attach to Permit

SIGNATURE: *Lonnie Erwin,*
Chief Plumbing and Mechanical Inspector
City of Dallas