

PLUMBING AND MECHANICAL
INTERPRETATION MANUAL



CODE: 2000 IPC & IRC

DATE:

CODE REF: IPC Sec. 504.6.1 IRC 2803.6.1

4/1/2004

SUBJECT: Temperature and Pressure Relief Drains

The code requires relief valve drains to be extended to the outside of the building or to an approved indirect waste receptor located inside the building.

When a sink is installed that requires the waste to be discharged into a sump and pumped to an approved drain, the sump will not be considered an approved location to drain a temperature and pressure relief valve.

SIGNATURE: *Lonnie Erwin,*

Chief Plumbing and Mechanical Inspector
City of Dallas